

vvlCurrentStatus	ID	facilityName	comments_Second	county	Expr1	Expr2	latitude	longitude
NonOp	14581001	CITY OF BRAZORIA - CITY OF BRAZORIA WWTP	#5- Chlorination system was not operational. The operator was in the process of diagnosing the issue. One of the three aeration paddles were broken. The plant lost all solids. Scheduled to receive several seed loads within the next few days. #11- Locatio	Brazoria	David Jordan	979-798-4075	29.016666	-95.585277
NonOp	1031000	GREENS BAYOU ELECTRIC GENERATING STATION WWTP	The facility was shut down and is in the process of starting up. The process may take over a week to complete. As of 9/13/17 all wastewater is being stored onsite and will be sent through the treatment unit once the facility is back online. The treatment	Harris	Mary Larsen	713-876-1686	29.820833	-95.219444
NonOp	11713001	CEDAR BAYOU PARK UTILITY DISTRICT - CEDAR BAYOU PARK WWTP	2. Flooded with 9 feet of water. Nothing is working. 3. Temporary outage. All electrical pumps down. No insurance company has visited. Sending waste water to Baytown. Has a verbal agreement with City of Baytown.	Harris	Jerald Landis	281-488-4115	29.799762	-94.925949

NonOp	1006000	CHEVRON PHILLIPS CEDAR BAYOU CHEMICAL PLANT	Electrical pump and substation had minor damage. 5. Dont have enough generators. 7. Water being contained on site. 10. Not ND 11. River flooded the plant. The plant is on generators. Will be on generator power for several weeks. WWTP is shut down and	Harris	Jerry Jurboe	281-421-6879	29.825277	-94.921944
NonOp	10932001	HARRIS COUNTY - BEAR CREEK PIONEERS PARK WWTP	Plant is still underwater; Mr. Darrell Kelly has been unable to get to plant except by boat. No status changes between now and 09/06/2017.	Harris	Darrell Kelly	281-910-0151	29.828227	-95.623186
NonOp	10495109	CITY OF HOUSTON - TURKEY CREEK WWTP	Entire plant was flooded, but not flooded now. Currently discharging with disinfection, utilizing portable generator for chlorine chamber. Disinfecting raw sewage. Main generator currently down, being repaired off grid. Need power to full assess damage.	Harris	Heather Maloney	832-395-5756	29.76751	-95.62071

DES	4633000	MCDONOUGH MARINE SERVICE CHANNELVIEW	2. Very low flow at this facility. Pump and haul being utilized. No discharge currently taking place. Disconnected. Portable system at facility. Pump and haul from 250 gallon tank pumping weekly.	HARRIS	Robert Spencer	281-452- 5887	29.79157	-95.07933
NonOp	3530000	PORT ARTHUR PRODUCTS STATION	The collection system is not operational at this time because the pumps flooded.	Jefferson	Lisa Gilbreath	832-256- 2482	29.886111	-93.994444
NonOp	12088001	US ARMY CORPS OF ENGINEERS - ROCKY CREEK PARK WWTP	Park is closed and no inflows to WWTP are occurring. WWTP has been turned off and is idle. Lift station is under water and extent of damage throughout system is unknown. Contact indicated would likely be the end of October before plant can be accessed	Washington	Randall McCartney	979-596- 1624	30.28546	-96.57331
NonOp	11916001	P C S DEVELOPMENT COMPANY - PARKVIEW SUBDIVISION WWTP	Influent lift station and chemical feed facilities were flooded. Chlorine building on side, 2-150# chlorine cylinders unsecured. New power feed to facility not connected to plant.	Orange				